APPENDIX V

MINIMUM STANDARDS FOR PARKING STALLS, AISLES AND MODULES

(See Diagram which follows)

On <u>Diagram</u>	Dimensions Based on the Angle of Parking		
A	The angle of parking 45°	60°	90°
В	Width of stall9'	9'	9'
C	Stall width, parallel to aisle12'9"	10'5"	9'
D	Stall depth, perpendicular to aisle	21'	18'
E	Stall length	19'	18'
F	Aisle width	17'*	24'
G	MODULES (consist of two rows of parking stalls and one aisle)		
	Interlock47'	55'	
	Wall to wall53'	59'	60'

^{*} One way aisle only

- ** 1. Exterior ramp grades shall not exceed 6°. Interior ramp grades shall not exceed 10°. Handicapped ramp grades shall be 1" per 1'.
 - 2. Where parallel parking is permitted, the stall length shall be 24 feet and aisle width shall be a minimum of 14 feet.
 - 3. Parking space(s) for the physically handicapped shall be designed in accordance with State requirements.

(Amended by Ord. No. A-834-12-04)